



Certificate of Compliance

This certificate is issued for the following:

PIPE FITTINGS - WELDED PIPE OUTLETS

The following items are FM Approved for Sigma Piping Products when manufactured at the plant listed below.

Product Designation	Nominal Run Pipe Size, in.	Nominal Outlet Pipe Size, in.	Max Working Pressure, psi (kPa)
Uni-let Weldolet	1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8	1/2	300 (2070)
Uni-let Weldolet	1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8	3/4	300 (2070)
Uni-let Weldolet	1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8	1	300 (2070)

Manufactured by:

Sigma Piping Products
700 Goldman Dr.
Cream Ridge, NJ 08514

FM Approvals Class: 1920

Approval Identification: 3032620 Approval Granted: April 10, 2009

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

Richard B. Dunne
Group Manager – Hydraulics Group
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

October 25, 2010